



Phosphate Mine Application - Florida

3-month test, 10 gpm



Species	Inlet (ppm)	Outlet (ppm)	% Reduction
TDS	3,049	430	85.9%
Sulfate	2,620	360	86.3%
Phosphate	141	22	84.4%